



MACON Butterfly valves

Butterfly valve with male end/female end + nut - 316L stainless steel





Specifications

Dimensions: DN40 to DN100 Connection: MACON male/female thread Operating pressure:

• 12 bar from DN40 to DN70

 10 bar from DN80 to DN100
Temperature: -20°C to +150°C (depending on the gasket)

Material: 316L stainless steel




Béné Inox – II chemin de la Pierre Blanche – 69800 SAINT-PRIEST – S.A.S with 240 000 € share capital – SIREN N° 311 810 287 Tel. N°: +33 (0)4 78 90 48 22 – Fax N°: +33 (0)4 78 90 69 59 – <u>www.bene-inox.com</u> – <u>bene@bene-inox.com</u>


Technical information, illustrations and photographs are provided for information only, they are not contractual. Some may vary according to the tolerances accepted in the profession and the applicable standards. All instructions for use, disassembly and maintenance are recommendations only. These could also vary depending on product usage conditions, its installation environment and purchaser requirements – of which the purchaser alone is responsible for their definition.

F









COUPE A-A


DN	D1	D2	F	L1	L2	S	М	ØT	ØP	α	Weight
(mm)	(mm)	(mm)	(mm)	(mm)	(mm)	(mm)	(mm)	(mm)	(mm)	(°)	(kg)
40	70	92	M55x3	44	21.5	8 (flat side)	M6	6.4	81	21	1.46
50	80	105	M67x3	44	21.5	8 (flat side)	M6	6.4	93	18	1.82
60	95	112	M79x3.5	44	21.5	8 (flat side)	M6	6.4	99	18	2.10
70	106	125	M90x3.5	44	21.5	8 (flat side)	M6	6.4	112	15	265
80	118	139	M102x4	60	13.5	9.5x9.5 (square)	M6	-	-	-	4.30
100	139	162	M125x4	64	13.5	9.5x9.5 (square)	M5	-	-	-	5.57

DN (mm)	Part number EPDM/316L	Part number Silicone/316L	Part number FKM/316L
40	664315-40	664334-40	664344-40
50	664315-50	664334-50	664344-50
60	664315-60	664334-60	664344-60
70	664315-70	664334-70	664344-70
80	664315-80	664334-80	664344-80
100	664315-100	664334-100	664344-100

Béné Inox – II chemin de la Pierre Blanche – 69800 SAINT-PRIEST – S.A.S with 240 000 € share capital – SIREN N° 311 810 287 Tel. N°: +33 (0)4 78 90 48 22 – Fax N°: +33 (0)4 78 90 69 59 – <u>www.bene-inox.com</u> – <u>bene@bene-inox.com</u>







N°	Part Name	Material		
1	BUTTERFLY	AISI 316L		
2	THREADED END FLANGE	AISI 304L/AISI 316L		
3	GASKET	EPDM/FKM/SILICONE		
4	BOLT	A2-70		
5	NUT	A2-70		
6	SHAFT PLUG	SILICONE		


Béné Inox – II chemin de la Pierre Blanche – 69800 SAINT-PRIEST – S.A.S with 240 000 € share capital – SIREN N° 311 810 287 Tel. N°: +33 (0)4 78 90 48 22 – Fax N°: +33 (0)4 78 90 69 59 – www.bene-inox.com – bene@bene-inox.com





Pressure and temperature

For pressure/temperature ratings, see the graph below.





Warning: If the butterfly valve is used with fluids that have a temperature above 60°C then people could burn themselves if they touch it.

Fluids

This value is suitable for non-abrasive and non-coagulable fluids, as long as the fluids are chemically compatible with the value parts that they can come into contact with.


Béné Inox – II chemin de la Pierre Blanche – 69800 SAINT-PRIEST – S.A.S with 240 000 € share capital – SIREN N° 311 810 287 Tel. N°: +33 (0)4 78 90 48 22 – Fax N°: +33 (0)4 78 90 69 59 – <u>www.bene-inox.com</u> – <u>bene@bene-inox.com</u>





64315/64334/64344-B V1124

Pressure drop (diagram)



Assembly and maintenance instructions

Installation

You can install the butterfly valve in any position. However, check that all fluids can flow through it freely, so that no fluid remains inside the valve when it is in use.

Check that there is enough space to move the valve's handle and to carry out maintenance operations where you are planning to install the valve.

Check that all piping is perfectly aligned and that the piping support structure is dimensioned so that the check value is not subject to any external stresses. The piping support structure must only support the pipes, not the butterfly value.

Clean the installation and check that the equipment is clean and free from foreign bodies that could damage the butterfly valve.

Check the valve is operating correctly.

Pressure test the installation according to the relevant standards (e.g. EN 12266-1) but do not exceed the valve's specifications.

Béné Inox – II chemin de la Pierre Blanche – 69800 SAINT-PRIEST – S.A.S with 240 000 € share capital – SIREN N° 311 810 287 Tel. N°: +33 (0)4 78 90 48 22 – Fax N°: +33 (0)4 78 90 69 59 – www.bene-inox.com – bene@bene-inox.com





64315/64334/64344-B V1124

Maintenance

You may need to change some of the butterfly valve's parts due to wear and tear or if a fluid has damaged the valve and caused a leak or malfunction. If this is the case see the "Assembly / Disassembly" section below.

Assembly / Disassembly

The maintenance and removal/installation of the butterfly valve must be carried out by personnel who are qualified and trained for this type of intervention.



Warning: Before you work on the valve, check that the installation has been stopped and that the piping is empty and is not pressurised.

Warning: If the butterfly valve is used with fluids that have a temperature above 60°C then people could burn themselves if they touch it.

Warning: Beware of hazardous materials - follow the instructions provided by the suppliers.

Remove the handle or the actuator (see the relevant product data sheet).

Unscrew the bolts 4 and remove the four nuts 5 holding the end flanges 2.

Separate the two end flanges 2 and take out the butterfly value 1 +gasket 3 assembly.

Remove the shaft plug 6 from underneath the

butterfly's shaft. Remove the worn gasket.



Warning: Take care not to damage the butterfly if you use a sharp tool (e.g. a cutter) to cut the gasket.

Warning: Check the condition of the butterfly: there should not be any scratches on the shaft, any dents on the disc nor any deposit build up, etc.

How to install a new gasket:

Lightly lubricate the butterfly valve shaft (at both ends).



Warning: Grease based products are generally not suitable for EPDM gaskets – only use soapy water or food-grade silicone grease (e.g. Klüber Paralic GTE703) with EPDM gaskets. Warning: For FKM or SILICONE gaskets use a 'conventional' food-grade oil or grease.

Béné Inox – 11 chemin de la Pierre Blanche – 69800 SAINT-PRIEST – S.A.S with 240 000 € share capital – SIREN N° 311 810 287 Tel. N°: +33 (0)4 78 90 48 22 – Fax N°: +33 (0)4 78 90 69 59 – <u>www.bene-inox.com</u> – <u>bene@bene-inox.com</u>

Technical information, illustrations and photographs are provided for information only, they are not contractual. Some may vary according to the tolerances accepted in the profession and the applicable standards. All instructions for use, disassembly and maintenance are recommendations only. These could also vary depending on product usage conditions, its installation environment and purchaser requirements – of which the purchaser alone is responsible for their definition.





First insert the longer part of the butterfly's shaft 1 into the gasket 3, then insert the shorter part by bending the gasket. For small diameters (DN40 and DN50), bend the gasket 3 by flattening it along the butterfly 1 while levering it with a non-sharp round tool (e.g. a screwdriver with a blade that has been cut/filed, rounded and polished). See the photos below.




For valve's from DN63 and above, bend the gasket manually without using any tools.

Once the gasket 3 has been fitted to the butterfly, insert the assembly between the valve's two end flanges 2, with the longer part of the butterfly's shaft on the side with the two actuator mounting holes. Leave the butterfly slightly open.

Position the four bolts 4 (with the bolt heads on the same side of the valve) and the four nuts 5.

Tighten the four nuts in a criss-cross pattern.

Refit the shaft plug 6 under the butterfly's shaft.



Pressure test the valve and check that it can be opened and closed before you put the installation back into service.

Béné Inox – II chemin de la Pierre Blanche – 69800 SAINT-PRIEST – S.A.S with 240 000 € share capital – SIREN N° 311 810 287 Tel. N°: +33 (0)4 78 90 48 22 – Fax N°: +33 (0)4 78 90 69 59 – <u>www.bene-inox.com</u> – <u>bene@bene-inox.com</u>





Accessories

Here is a list of all of our butterfly valve accessories:

Butterfly valve gaskets

- Model 61317: EPDM gasket for butterfly valves
- Model 61318: Silicone gasket for butterfly valves
- Model 61319: FKM gasket for butterfly valves

Butterfly valve butterflies

- Model 61316: Butterfly for butterfly valve

Butterfly valve handles

- Model 61320: Stainless steel lever with plastic handle for butterfly valves Ø25 to Ø76
- Model 61322: Plastic handle with trigger for butterfly valves Ø25 to Ø76
- Model 61343: Plastic multi-position handle with trigger for butterfly valves Ø25 to Ø76
- Model 61344: Stainless steel multi-position handle with trigger for butterfly valves Ø25 to Ø76
- Model 61323: Stainless steel multi-position pull tab handle for butterfly valves Ø25 to Ø104
- Model 61345: Stainless steel lockable pull tab handle for butterfly valves Ø25 to Ø104
- Model 61346: Stainless steel open/closed position pull tab handle for butterfly valves Ø25 to Ø104
- Model 61324: Stainless steel lever with plastic handle for butterfly valves Ø25 to Ø76
- Model 61347: Stainless steel lever and handle for butterfly valves Ø25 to Ø76

Micrometric handles for flow adjustment

- Model 61325: Micrometric handle for flow adjustment for butterfly valves Ø25 to Ø104

Pneumatic actuators

- Model 61326: Spring return 1/4-turn pneumatic actuator
- Model 61327: Double-acting type 1/4-turn pneumatic actuator
- Model 61301: Small size spring return 1/4-turn pneumatic actuator
- Model 61302: Small size double-acting type 1/4-turn pneumatic actuator





Pneumatic and electric actuators

- Model 61520: Aluminium pneumatic actuator with fixing bracket spring return or double-acting type
- Model **61521**: Stainless steel pneumatic actuator with fixing bracket spring return or double-acting type
- Model 61523: Electric actuator UMA with fixing bracket IP65
- Model 61527: Electric actuator ER+ with fixing bracket IP66
- Model 61528: Fail-safe electric actuator ER+ with fixing bracket IP66
- Model 61529: Positioner electric actuator ER+ with fixing bracket IP66
- Model 61531: Electric actuator VR with fixing bracket IP68
- Model 61532: Fail-safe electric actuator VR with fixing bracket IP68
- Model 61533: Positioner electric actuator VR with fixing bracket IP68

Standards and compliance

- This valve complies with European Pressure Equipment Directive (PED) 2014/68/EU Article 4 paragraph 3 (formerly 97/23/EC Article 3 paragraph 3).
- This valve complies with EC Directive 1935/2004.